

OFFICE USE ONLY
 Log No. 83933
 Permit No. _____
 Basin 85
 NOTICE OF INTENT NO. 45056

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BRETT HAMMOND ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5010 Cassandra Way Alamosa Drive
Reno, Nevada 89523 Sparks, Nevada 89436
 2. LOCATION SW 1/4 NW 1/4 Sec. 18 T. 21N N/S R. 21 E. Washoe County
 PERMIT NO. Waiver R-382 076-360-78 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. BORE HOLE #1 LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Decomposed granite | | 0 | 8 | 8 |
| Weathered granite | | 8 | 23 | 15 |
| Rusty weathered granite soft | | 23 | 27 | 4 |
| Weathered granite | | 27 | 111 | 84 |
| Soft zone, clay | | 111 | 113 | 2 |
| Weathered granite | | 113 | 216 | 103 |
| Softer weathered granite | | 216 | 281 | 65 |
| Soft zone, rusty | | 281 | 284 | 3 |
| Weathered granite | | 284 | 348 | 64 |
| Gray hard granite | | 348 | 465 | 117 |
| Weathered granite, some clay streaks | | 465 | 467 | 2 |
| Gray hard granite | | 467 | 538 | 71 |
| Soft granite with some clay streaks (NO WATER) | | 538 | 542 | 4 |
| Gray hard granite | | 542 | 554 | 12 |
| Fracture (NO WATER) | | 554 | 555 | 1 |
| Gray hard granite | | 555 | 660 | 105 |
| Softer granite weathered | | 660 | 735 | 75 |
| Fracture | X | 735 | 737 | 2 |
| Gray granite | | 737 | 777 | 40 |
| Fracture | X | 777 | 778 | 1 |
| Gray granite | | 778 | 789 | 11 |
| Fracture | X | 789 | 790 | 1 |
| Gray granite | | 790 | 803 | 13 |
| Casing, 6 5/8" was dropped 406 ft. to bottom. | | | | |
| Went in to "fish" it out, seized in the hole. | | | | |
| ABANDON as per waiver R-382, May 29, 2001 (below) | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 803 Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 803 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | | .188 | 383 | 789 |
| | | | | |
| | | | | |

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started May 21, 2001, 19_____
 Date completed May 30, 2001, 19_____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| Cont. from above | | | |
| Top of casing @383 feet | | | |
| Top of gravel @364 feet | | | |
| Top of bentonite chips @349 feet | | | |
| Backfilled with drillcuttings from 349-10 ft. | | | |
| Cement seal 10-0 feet | | | |

DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the 923 Division of Water Resources, the on-site driller.
 Signed [Signature]
 Date May 11, 2001