

OFFICE USE ONLY
 Log No. 83935
 Permit No. _____
 Basin. 8.5

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47095

1. OWNER BRETT HAMMOND ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5010 Cassandra Way Alamosa Drive
Reno, Nevada 89523 Sparks, Nevada 89436
 2. LOCATION SW 1/4 NW 1/4 Sec 18 T. 21N N/S R 21 E Washoe County
 PERMIT NO. 076-360-78 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. BORE HOLE #2 LITHOLOGIC LOG 20' S of Bore #1

Material	Water Strata	From	To	Thick-ness
Decomposed granite		0	1	1
Weathered granite		1	19	18
Rusty granite		19	24	5
Weathered granite		24	97	73
Soft zone		97	99	2
Weathered granite		99	179	80
Soft rusty granite		179	187	8
Weathered granite		187	231	44
Softer weathered granite with clay streaks		231	274	43
Weathered harder granite		274	308	34
Soft zone (NO WATER)		308	309	1
Harder weathered granite		309	339	30
Gray hard granite		339	346	7
Gray hard granite		346	453	107
Weathered granite with clay streaks		453	471	18
Gray granite		471	659	188
Fracture (NO WATER)		659	660	61
Gray granite		660	732	72
Fracture	X	732	734	2
Softer weathered granite		734	778	44
Fracture	X	778	779	1
Gray granite		779	792	13
Fracture	X	792	793	1
Gray granite		793	803	10

8. WELL CONSTRUCTION
 Depth Drilled 803 Feet Depth Cased 803 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 803 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>803</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 738 feet to 798 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 803 feet

9. WATER LEVEL
 Static water level 700 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc. driller performing actual drilling on site or contractor
 Date May 11, 2001

Date started May 30, 2001, 19____
 Date completed June 4, 2001, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>			