

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44307

1. OWNER Larry Barnes ADDRESS AT WELL LOCATION 505 Two Forty Rd Reno NV 89510
 MAILING ADDRESS 505 Two Forty Rd Reno NV 89510
 2. LOCATION NE 1/4 SW 1/4 Sec. 35 T. 23 N/S R. 20 E. Washoe County Palomino Valley
 PERMIT NO. 69025 Parcel No. 076-110-35 Subdivision Name Palomino Valley
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other M.V.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	18	18
Clay		18	20	2
Sand		20	155	135
Clay		155	160	5
Sand		160	187	27
Clay		187	190	3
Sand		190	205	15
Clay		205	215	10
Sand		215	260	45
Clay		260	262	2

(Vertical stamp: 58)

8. WELL CONSTRUCTION
 Depth Drilled 262 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 262 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 CASING SCHEDULE Closed Bottom

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17</u>	<u>3/16</u>	<u>2+</u>	<u>260</u>

Perforations:
 Type perforation Saw Slot
 Size perforation 3/32 x 3.5 x 8 Around
 From 260 feet to 220 feet
 From 180 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 262 feet

9. WATER LEVEL
 Static water level 107 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 57 °F Quality 700 T.D.S.

Date started 6/27/01
 Date completed 7/9/01

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>100+</u>	<u>N.A.</u>	<u>8</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olenki Drilling & Pump Co. Contractor
 Address 15045 Red Rock Rd. Contractor
Reno NV. 89506
 Nevada contractor's license number 50343 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1656 Division of Water Resources, the on-site driller.
 Signed John F. Olenki
 By driller performing actual drilling on site or contractor
 Date 7/11/01