

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45795
5 Pinyon Pine Lane

1. OWNER Chris Crookshanks ADDRESS AT WELL LOCATION 5 Pinyon Pine Lane
 MAILING ADDRESS P.O. Box 150464
Ely, Nevada 89301

2. LOCATION SE 1/4 NE 1/4 Sec. 27 T 16 N 63 E White Pine County
 PERMIT NO. _____ APN 10-690-58

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand & Small Gravel		3	30	27
Sand & Course Gravel		30	40	10
Sand & Small Gravel		40	75	35
Clay & Small Gravel		75	105	30
Clay & Course Gravel		105	115	10
Clay & Small Gravel		115	165	50
Brown Clay		165	265	100
Clay with Water	X	265		
Bearing Gravel Stringers			290	25
Brown Clay		290	330	40
Clay with Sand & Gravel X		330		
Water Bearing Stringers			350	20
Brown Clay		350	363	13

8. WELL CONSTRUCTION
 Depth Drilled 363 Feet Depth Cased 363 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 363 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	363

Perforations: Factory
 Type perforation 178" x 2" 6 Rows
 Size perforation 178" x 2"
 From 262 feet to 363 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 363 feet

9. WATER LEVEL
 Static water level 263 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 56 °F Quality Good

Date started July 19, 2001
 Date completed July 23, 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	97	1 1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue
Ely, Nevada 89301 Contractor
 Nevada contractor's license number 14790
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1793
 Division of Water Resources, the on-site driller
 Signed Reid Lewis By Marshall D. Christiansen
 By driller performing actual drilling on site or contractor
 Date July 30, 2001