

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45061

1. OWNER JOE & LINDA REICHLIN ADDRESS AT WELL LOCATION 9630 N. Virginia Street  
 MAILING ADDRESS 15650 Toll Road Reno, Nevada 89511 Reno, Nevada 89506  
 2. LOCATION NE 1/4 NW 1/4 Sec 16 T 20N N/S R 19 E Washoe County Washoe  
 PERMIT NO. 082-650-18 Washoe County  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay with boulders & gravel		1	18	17
Soft brown sandy clay		18	23	5
Brown sandy clay		23	38	15
Brown sandy clay, soft		38	52	14
Brown sandy clay with gravels		52	89	47
Soft zone (NO WATER)		89	91	2
Brown sandy clay		91	146	55
Soft zone		146	148	2
Brown sandy clay		148	236	88
Soft zone (maybe 2 GPM) X		236	240	4
Brown sandy clay with gravels		240	363	23
Weathered granvels		363	405	42
Fracture rock X	X	405	435	30
Weathered granite		435	450	15

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 450 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 100 Feet  
 8 5/8 Inches 100 Feet 450 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	450

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 399 feet to 439 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 450 feet

9. WATER LEVEL  
 Static water level 195 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board.  
 Nevada driller's license number 923 issued by the  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date May 21, 2001

Date started May 14, 2001 19\_\_\_\_  
 Date completed May 16, 2001 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		