WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83962
Permit No.
Basin 105

NOTICE OF INTENT NO. 44915

1. OWNER Paul Juergens
MAILING ADDRESS 627 Appaloosa Ln.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 627 Appaloosa
Gardnerville Nv.

2. LOCATION SE 1/4 SW 1/4 Sec. 24 T 12N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 1220-24-801-011 (Parcel No.) Ruhenstroth (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented gravel	no	125	137	12
unsorted sand and	yes	137		
gravel			149	12
Cemented gravel	no	149	162	13
med. sorted gravel	yes	162	205	43

RECEIVED
01 MAY 15 AM 11:12
STATE ENGINEER'S OFFICE

Date started 3/30/2001, 19__
Date completed 4/2/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
+ 25		1 Hr

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	125	Feet	205	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	125	225

Perforations:
Type perforation Factory milled
Size perforation .060 6 Row
From 185 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal N/A
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From no feet to feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 4/2/2001

USE ADDITIONAL SHEETS IF NECESSARY