

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83965
 Permit No. 710
 Basin 710
 NOTICE OF INTENT NO. **46946**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **KARL LIND**
 MAILING ADDRESS **3920 SOUTH 1100 EAST**
SALT LAKE CITY, UT 84124

ADDRESS AT WELL LOCATION **RUBY VALLEY** County

2. LOCATION **SE 1/4 SW 1/4 Sec. 15 T 31N**
 PERMIT NO. **007-280-019**
Issued by Water Resources Parcel No.

N/S R **59E E** **ELKO** County
TRACT OF LAND
Subdivision Name

3. WORK PERFORMED
 New Well
 Deepen
 Replace
 Abandon
 Recondition
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Air
 Rotary
 Other RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	1	1
BOULDERS		1	12	11
BOULDERS & CLAY		12	60	48
BOULDERS, SAND & GRAVEL	110	60	120	60

8. WELL CONSTRUCTION
 Depth Drilled **120** Feet
 Depth Cased **120** Feet
HOLE DIAMETER (BIT SIZE)
 From **10 5/8** Inches To **120** Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	120

Perforations:
 Type perforation **MILLSLOT**
 Size perforation **3/16 X 3**
 From **100** feet to **120** feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **100**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From **100** feet to **120** feet

9. WATER LEVEL
 Static water level **37** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **C** °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started **07/17/2001**
 Date completed **07/19/2001**

Name **HACKWORTH DRILLING, INC** Contractor
 Address **P.O. BOX 850** Contractor

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	X Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
45		4	

ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board **020582**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**
 Signed *Dennis Dawson*
By driller performing actual drilling on-site or contractor
 Date **07/20/2001**