WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83978
Permit No.
Basin 92A

NOTICE OF INTENT NO. 47098

1. OWNER J&L CONSTRUCTION/LARRY LIKES
MAILING ADDRESS 10400 Redrock Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 10810 Osage Road
Reno, Nevada 90506

2. LOCATION SE ¼ NE ¼ Sec 25 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-172-07 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	3	2
Coarse granite sands		3	11	8
Brown sandy clay		11	33	22
Granite sands		33	35	2
Brown sandy clay		35	55	20
Soft sandy clays		55	65	10
Soft granite sands with clay streaks	X	65	88	23
Coarse sands		88	99	11
Brown clay		99	100	1

Date started June 26, 2001, 19
Date completed June 26, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	100 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	100

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 75 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. 60 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed (By driller performing actual drilling on site or contractor)

Date June 28, 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627