

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 83995  
 Permit No. \_\_\_\_\_  
 Basin 1602

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22400

1. OWNER FANNIN, SHIRLEY ADDRESS AT WELL LOCATION 2610 ZEPHYR AVE  
 MAILING ADDRESS 2610 ZEPHYR PAHRUMP, NV 89048

2. LOCATION NE 1/4 SW 1/4 Sec. 29 T 20S N/S R 53E E NYE County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources 40-241-06 Parcel No. CALVADA VALLEY Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	76	76
CALICHIE	WB	76	81	5
CLAY		81	109	28
CALICHIE	WB	109	113	4
CLAY		113	127	14
CALICHIE	WB	127	132	5
CLAY		132	153	21
CALICHIE	WB	153	160	7

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10.25 Inches To 0 Feet  
 From 160 Feet To \_\_\_\_\_ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/8 X 3

From	To
<u>120</u> feet	<u>160</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet



Date started 7/11/2001, 19\_\_\_\_  
 Date completed 7/13/2001, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor  
 Address P.O. BOX 4220 Contractor  
PAHRUMP, NV. 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 7/31/01