WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84008
Permit No. 87
Basin

NOTICE OF INTENT NO. 42100

1. OWNER Washoe County Dept. of Water Resources
MAILING ADDRESS 4930 Energy Way Reno, NV. 89821
ADDRESS AT WELL LOCATION 853 Haskell Street (APN-11-331-3)

2. LOCATION SE ¼ NE ¼ Sec. 14 T. 19 N R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other None

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand		0'	7'	7'
Gravel		7'	16'	9'
Coarse Sand		16'	24'	8'
Silty Sand		24'	33'	9'
Coarse Gravel		33'	37'	4'
Boulder		37'	38'	1'
Sand Medium Coarse		38'	44'	6'
Fine Gravel		44'	46'	2'
Ryolitic Boulder		46'	50'	4'
Coarse Sand		50'	52'	2'
Silty Sandy Gravel		52'	70'	18'
Granite Boulder		70'	71'	1'
Silty Sandy Gravel		71'	180'	109'

RECEIVED
DIVISION OF WATER RESOURCES

Date started 4-2-01, 19
Date completed 4-4-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0' Feet	100' Feet
6" Inches		100' Feet	180' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch. 80	0'	178'

Perforations:
Type perforation Factory Cut
Size perforation 0.020"
From 178' feet to 158' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0'-17' Cement Grout 17'-146' Quick Grout 146'-151' Bent. Pellets
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 178' feet to 151' feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer for Bert Longyear (Contractor)
Address 32 Stokes Dr. Dayton, NV. 89403 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed Phillip E. Cramer (By driller performing actual drilling on site or contractor)
Date 5-16-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627