WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84009
Permit No.
Basin 87

NOTICE OF INTENT NO. 42097

1. OWNER Washoe County Department of Water Resources
MAILING ADDRESS 4930 Energy Way
Reno, NV. 89821

ADDRESS AT WELL LOCATION Harvard Way
West Side of Street Near North East Corner

2. LOCATION NW ¼ NW ¼ Sec. 18 T. 19 N/S R. 20 E. Washoe County

PERMIT NO. Issued by Water Resources | Parcel No. 1331-314-7 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel, cobbles, boulders		0'	35'	35'
Wet Gravel & cobbles		35'	47'	12'
Silt		47'	50'	3
Cobbles & Gravelly Sand		50'	91'	41'
Sandy Silt with minor Clay		91'	109'	18'
Sandy Gravel with Small cobbles		109'	346'	237'

Date started 3-22-01, 19
Date completed 3-30-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 346' Feet Depth Cased 346' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0' Feet	150' Feet
5½" Inches		150' Feet	346' Feet
6" O.D. Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch. 80	+5'	346'

Perforations:
Type perforation Factory Cut
Size perforation 0.020
From 326' feet to 346' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0'-24' Placement Grout
Placement Method: ☑ Pumped 24'-310' volclay Grout
☐ Poured
Gravel Packed: ☑ Yes ☐ No 310'-314' Bent. Pellets
From 314' feet to 346' feet

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 35' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer for Boart Longyear (Contractor)
Address 32 Stokes Dr. Dayton, NV. 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed Phillip E. Cramer
By driller performing actual drilling on site or contractor
Date 5-9-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627