WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84014
Permit No.
Basin 05

NOTICE OF INTENT NO. 44921

1. OWNER Elton Crowley
MAILING ADDRESS 790 Pawanee
Minden, NV 89423

ADDRESS AT WELL LOCATION 790 Pawnee Minden, Nv.
89423

2. LOCATION SE 1/4 NE 1/4 Sec. 12 T 14N N/S R 19E E Douglas County
PERMIT NO. Issued by Water Resources | 13-080-28 Parcel No. | Subdivision Name

3. WORK PERFORMED
[ ] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Br. DG with clay	no	0	14	14
Br. DG course sand	no	14	118	104
Gray DG with clay	No	118	129	11
Gray DG course sand	yes	129	160	31

Date started 7/12/2001 , 19__
Date completed 7/17/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		2 Hrs

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	60	Feet
9 7/8	Inches	60	Feet	160	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	160

Perforations:
Type perforation Factory Milled
Size perforation 1/8 X 3 6 row
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 111ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eddo Explortion Inc. Contractor
Address 7780 Curry Rd. Contractor
Fallon Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on-site or contractor
Date 8/4/2001

USE ADDITIONAL SHEETS IF NECESSARY