WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84021
Permit No.
Basin 89

NOTICE OF INTENT NO. 34836B

1. OWNER George Gillemot
MAILING ADDRESS 4814 Old Hwy 395
Carson City, NV 89704

ADDRESS AT WELL LOCATION 4814 Old Hwy 395

2. LOCATION SE 1/4 SW 1/4 Sec. 3 T 16N N/S R 19E E Washoe County
PERMIT NO. WaCo# 6933 Issued by Water Resources
055-042-19 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" well that had a 5" PVC liner installed and gravel packed. We first tried to pull the 5" liner, but were not successful. The 5" liner pulled in two. The perforations in the liner were from 100-145'. We pumped 1.75 cu yards of neat cement mixed 5.2 gallons of water per sack and filled from the bottom to the top using pressure grout machine and tremie tube. We cut the top 3" off of the casing.				

RECEIVED
01 JUL 30 AM 11:52
STATE ENGINEER'S OFFICE

Date started 7/18/2001, 19__
Date completed 7/18/2001, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Factory
Size perforation 3/32" x 3" and screen
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 145
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 7/23/01

USE ADDITIONAL SHEETS IF NECESSARY