WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84068
Permit No. 66979
Basin 184

well #3
NOTICE OF INTENT NO. 20959

1. OWNER URS Corporation
MAILING ADDRESS 7115 Amigo St. Ste. #110
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION Meadow Valley
North of Glendale, NV

2. LOCATION NW ¼ NW ¼ Sec. 12 T 12 N/S R 65 E LIncoln County
PERMIT NO. W-2102 Issued by Water Resources 66979 Parcel No. 08-231-01 Subdivision Name N/A

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, gravel, cobbles		0	20	20
clay, sand, gravel, cobbles	X	20	220	200
Clay, some sand, gravel		220	245	25

Date started July 8, 2001, 19
Date completed July 11, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
350	20	3

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
25 Inches		0 Feet	54 Feet
19 Inches		54 Feet	245 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	sch 40	.250	0	54
14	sch 40	.250	+3	96.5
14	sch 40	.250	222	237

Perforations:
Type perforation Louvered
Size perforation .08
From 96.5 feet to 222 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 68
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 78 feet to 233 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (Contractor)
Address 2745 W. California Av. (Contractor)
Salt Lake City, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1959
Signed Mark Foster (By driller performing actual drilling on site or contractor)
Date 8/3/01

DENIED/DMG
RECEIVED
AUG 8 2001
LAS VEGAS

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

101-627