WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84080
Permit No.
Basin 102
NOTICE OF INTENT NO. 92063

1. OWNER Herb Gutemacher
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1235 HOOTEN ST SILVER SPRINGS, NV

2. LOCATION SE ¼ SE ¼ Sec 13 T 17 N/S R 24 E LYON County
PERMIT NO. Issued by Water Resources | Parcel No. 17-254-01 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DIRT/ROCK | | 0 | 15 | 15 |
| SAND/BROWN CLAY | | 15 | 25 | 10 |
| FRACTURED ROCK | | 25 | 130 | 105 |
| SAND/GRAVEL | X | 130 | 150 | 20 |

Date started 26 July 2001, 19
Date completed 26 July 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 1.5 |

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 9 7/8 Inches | | 0 Feet | 150 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 150 |

Perforations:
Type perforation Factory milled
Size perforation 3/32" X 3"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 150 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name
Contractor
Address Blain Drilling & Pump Co. P.O. Box 1255 Carson NV 89702
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson
By driller performing actual drilling on site or contractor
Date 7-29-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627