COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84123
Permit No.
Basin 105

NOTICE OF INTENT NO. 46261

1. OWNER BLAIN MCGUIRE CONSTRUCTION
MAILING ADDRESS 2110 LAKESHORE DRIVE
CARSONCITY , NV 89704

ADDRESS AT WELL LOCATION 1597 JONES ST
MINDEN , NV 89423

2. LOCATION SE ¼ SE ¼ Sec 34 T 14 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1420-34-710-060 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| OVERBURDEN | | 0 | 6 | 6 |
| COURSE SOFT SANDS | | 6 | 29 | 23 |
| COURSE DG SANDS | | 29 | 134 | 105 |
| BROWN SANDY CLAY | | 134 | 196 | 62 |
| BROWN GUMMY CLAY | | 196 | 205 | 9 |
| FRACTURED DG SANDS | XXX | 205 | 240 | 35 |

Date started 6/12 , 20 01
Date completed 6/15 , 20 01

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 45 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 3/4 Inches | 0 Feet | 240 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 240 |

Perforations:
Type perforation MILL SLOT
Size perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Hack
By driller performing actual drilling on site or contractor
Date 6/15/01

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429