WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84127
Permit No.
Basin 105

NOTICE OF INTENT NO. 45905

1. OWNER ARI + Tina MaKinen
MAILING ADDRESS PO Box 11521
South Lake Tahoe, Ca 96155
ADDRESS AT WELL LOCATION 1705 Hyde St
Minden, NV 89423

2. LOCATION S 1/2 1/4 NE 1/4 Sec. 2 T. 13 N/S R. 20 E/W Douglas County
PERMIT NO. — Issued by Water Resources
23-510-27 Parcel No.
N-A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	60	60'
Brown Clay		60'	80'	20'
Brown Sand + Clay		80'	120'	40'
Brown + Black Gravel		120'	140'	20'
Brown Clay		140'	155'	15'
Brown + Black Sand Gravel		155'	180'	25'
Brown Sand + Clay		180'	240'	60'
Grey Clay		240'	260'	20'
Grey Sand + Gravel		260'	300'	40'

Date started MAY 11, 2001, 19
Date completed MAY 16, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-30		4 HRS.

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation Factory
Size perforation
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 300 feet to 50 feet

9. WATER LEVEL
Static water level 231 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING (Contractor)
Address P.O. BOX 2227 (Contractor)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans
By driller performing actual drilling on site or contractor
Date 5-16-2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627