

#2052

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 84152
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45910

1. OWNER Bingo Construction ADDRESS AT WELL LOCATION
MAILING ADDRESS PO BOX 487 1226 Kimberling Rd
Minden, Nev 89423 Gardnerville, NV 89410
2. LOCATION NE 1/4 SE 1/4 Sec. 17 T. 12 N. R. 20 E Douglas County
PERMIT NO. 1220-17-801-002
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|-----------|------------|------------|
| <u>Brown White + Black Sand + Gravel</u> | | <u>0</u> | <u>50</u> | <u>50</u> |
| <u>Black + White Gravel</u> | | <u>50</u> | <u>90</u> | <u>40</u> |
| <u>Black + White + Orange Sand + Gravel</u> | | <u>90</u> | <u>120</u> | <u>30</u> |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 108 Feet
HOLE DIAMETER (BIT SIZE)
8 3/4 Inches From 0 Feet To 120 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4</u> | | | <u>71</u> | <u>88</u> |

Perforations:
Type perforation Factory
Size perforation
From 88 feet to 108 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 88 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No Bentonite Grout
From 86 feet to 108 feet

9. WATER LEVEL
Static water level 69 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cold °F Quality Good

Date started May 21, 2001, 19.....
Date completed May 23, 2001, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>30</u> | | <u>1 HR</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge
NEVADA PUMP & DRILLING
Name P.O. BOX 2227
Address DAYTON, NV 89403
Nevada contractor's license number 046357
issued by the State Contractor's Board
Nevada driller's license number issued by the 2187
Division of Water Resources, the on-site driller
Signed Thomas Evans
By driller performing actual drilling on site or contractor
Date June 4, 2001

RECEIVED
01 JUN 13 AM 11:35
STATE ENGINEERS OFFICE