

OFFICE USE ONLY  
 Log No. 84189  
 Permit No. 87  
 Basin 20320

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20320

1. OWNER KG Watters ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 4 T. 18 N. R. 20 E. Curvall County \_\_\_\_\_  
 PERMIT NO. 28 Issued by Water Resources Parcel No. 022-220-01 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  PVC  
 Air  Other Drift

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Fill</u>		<u>0</u>	<u>8</u>	
<u>Dirty Sand</u>		<u>8</u>	<u>21</u>	
<u>Sand &amp; gravel</u>		<u>21</u>	<u>37</u>	
<u>Clay</u>		<u>37</u>	<u>45</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 45 Feet Depth Cased 45 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 45 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>5/16</u>	<u>0</u>	<u>45</u>

 Perforations:  
 Type perforation Stol  
 Size perforation 032  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to 45 feet  
 From 10 feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 45 feet

Date started 6-25-01, 19\_\_\_\_\_  
 Date completed 6-25-01, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GC Contractor \_\_\_\_\_  
 Address \_\_\_\_\_ Contractor \_\_\_\_\_  
 Nevada contractor's license number 31248 issued by the State Contractor's Board  
 Nevada driller's license number 111968 issued by the Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6-25-01