WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84256
Permit No.
Basin 87

NOTICE OF INTENT NO. 47356

1. OWNER John Galvin
MAILING ADDRESS P.O. Box 2670
Reno, NV 89505

ADDRESS AT WELL LOCATION 1620 Catalpa Lane

2. LOCATION ____ 1/4 SW 1/4 Sec. 1 T 18N N/S R 19E E Washoe County
PERMIT NO. ____ Issued by Water Resources | 040-611-08 Parcel No. | Lakeside Meadows #3 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other ____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & cobbles		0	55	
sand		55	65	10
sandy clay		65	80	15
sand		80	120	40
clay w/gravel		120	130	10
sand		130	165	35
clay w/sand		165	250	85
consoldated sand		250	310	60

Date started 8/7/01, 19__
Date completed 8/9/01, 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
117		5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4 Inches		0 Feet	310 Feet
____ Inches		____ Feet	____ Feet
____ Inches		____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	120

Perforations:
Type perforation mill slot
Size perforation .060
From 120 feet to 300 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed ____ By driller performing actual drilling on-site or contractor
Date 8/20/01