

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 84399
 Permit No. 162
 Basin _____
 NOTICE OF INTENT NO. 22323

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Art Bell ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1230 W. Dutch Ford 1230 W. Dutch Ford
Pahrump, NV 89048
 2. LOCATION NW 1/4 NW 1/4 Sec. 20 T. 20S N/S R 53E E Nye County
 PERMIT NO. 36-423-08 Sunland Development
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>brown clay</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>grey clay</u>		<u>4</u>	<u>17</u>	<u>13</u>
<u>green clay</u>		<u>17</u>	<u>28</u>	<u>11</u>
<u>grey clay</u>		<u>28</u>	<u>36</u>	<u>8</u>
<u>grey caleche</u>	<u>x</u>	<u>36</u>	<u>58</u>	<u>22</u>
<u>See next line</u>	<u>x</u>	<u>58</u>	<u>62</u>	<u>4</u>
<u>grey clay with caleche strings</u>				
<u>brown clay</u>	<u>x</u>	<u>62</u>	<u>100</u>	<u>38</u>
<u>See next line</u>	<u>x</u>	<u>100</u>	<u>140</u>	<u>40</u>
<u>brown clay with caleche strings</u>				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 9/11/01 19____
 Date completed 9/11/01 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed _____ By driller performing actual drilling on-site or contractor
 Date 9-20-01

