

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21669

1. OWNER Raymond Weese ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Arlet Drive _____
Amargosa Valley, NV 89050 _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 1 T. 17 N. R. 48 E _____ County _____
 PERMIT NO. N/A Issued by Water Resources Parcel No. 19-681-21 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand		0	30	30
sand w/gravel		30	45	15
clay		45	62	17
clay w/gravel		62	90	28
limestone		90	98	8
gravel	<u>1st</u>	98	115	17
limestone		115	128	13
sand w/clay layers		128	148	20
tan clay		148	183	35
limestone		183	191	8
gravel w/ sand	<u>2nd</u>	191	197	6
limestone w/clay layers		197	220	23
Bottom of Hole			220	

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>180</u>
<u>Surface Protective Casings:</u>				
<u>7' X 8" Steel - 180'</u>				


Perforations:
 Type perforation Machined
 Size perforation 3" X 1/8" Every 12"
 From 100 feet to 140 feet
 From 180 feet to 210 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 220 feet



Date started 8-27-01 19_____
 Date completed 8-30-01 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge. **I**

Name Cook Drilling Co. Contractor
 Address HR 70 Box 6543 Contractor
Amargosa Valley, NV 89050
 Nevada contractor's license number 5376-A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
 Signed Randy Johnson
 By driller performing actual drilling on site or contractor
 Date Sept 26, 2001