WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84423
Permit No.
Basin 107

NOTICE OF INTENT NO. 45441

1. OWNER Ted R + DiANNeK Getter
MAILING ADDRESS P.O. Box 251
murphys Calif 95247
ADDRESS AT WELL LOCATION 18 Santa Theresa
Smith Nev 89430

2. LOCATION NE ¼ SE ¼ Sec 22 T 11 N N/S R 23 E Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 10-291-23
18 Santa Theresa Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Dg Top Soil | | 0 | 8 | 8 |
| Hardpan | | 8 | 10 | 2 |
| yellow Sandy clay | | 10 | 60 | 50 |
| Sand + gravel | X | 60 | 85 | 25 |
| Sandy Clay | | 85 | 96 | 11 |
| Coarse Sand | X | 96 | 120 | 72 |

Date started Aug 26, 01
Date completed Sept 5, 01

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 10 ft | 4 hrs |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 50 Feet |
| 6 Inches | | 50 Feet | 120 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | 188 | 0 | 120 |
| | | | | |

Perforations:
Type perforation Factory saw slot
Size perforation
From 90 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund A Miller Drilling Contractor
Address P.O. Box 92 Contractor
Smith Nev 89430
Nevada contractor's license number issued by the State Contractor's Board 23166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date 9-20-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627