WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84430
Permit No.
Basin 87

NOTICE OF INTENT NO. 39655

1. OWNER: NR Desert Institute
MAILING ADDRESS: Reno NV
ADDRESS AT WELL LOCATION: NW Experimental ST
Fleischman AGR Reno NV

2. LOCATION SW ¼ NE ¼ Sec. 16 T. 19 (N)S R. 20 E. Washoe County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG (5)

Material	Water Strata	From	To	Thickness
clay SAND		0	15	
cobbles		15	20	

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Factory	020	0	20

Perforations:
Type perforation 020
Size perforation Factory
From 0 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature cold °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Exploration Drilling (Contractor)
Address 1635 Belford Road (Contractor)
Reno NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2139
Signed (By driller performing actual drilling on site or contractor)
Date 4/17/01

Date started 4/14/01, 19
Date completed 4/15/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627