WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84437
Permit No.
Basin 69

NOTICE OF INTENT NO. 43400

1. OWNER Seth T. Bidegary
MAILING ADDRESS 1900 Bridge St., Paradise Valley, NV. 89426
ADDRESS AT WELL LOCATION 1900 Bridge St Paradise Valley, NV 89426

2. LOCATION NE ¼ SW ¼ Sec. 26 T. 42 N S R. 39 E. Humbolt County
PERMIT NO. N/A Issued by Water Resources
004-331-24 Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
hard Cemented Rock		0	20	
Cemented Rock w/S Brown Clay		20	40	
Decomposed gravel w/Brown Clay		40	60	
Decomposed gravel w/Clay		60	100	
DG w/Brown Clay		100	180	
DG w/Little Clay		180	220	
Sand & Clay		220	280	
Black gravel & Sand		280	300	

RECEIVED 01 OCT 25 AM 10:49 STATE ENGINEER'S OFFICE

Date started 9-13, 19 01
Date completed 10-5, 19 01

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		7

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.188		300

Perforations:
Type perforation Factory
Size perforation 3 in x 1/8
From feet to feet
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 30 feet to 300 feet

9. WATER LEVEL
Static water level 69 feet below land surface
Artesian flow 0 G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McNinch Drilling Contractor
Address 8005 McNinch Rd Contractor
Winnemucca, NV. 89446
Nevada contractor's license number issued by the State Contractor's Board 5437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-22-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627