WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8 94468
Permit No.
Basin 105

NOTICE OF INTENT NO. 45923

1. OWNER Steve Walker
MAILING ADDRESS 6641 Genoa Ln, Genoa, NV 89411
ADDRESS AT WELL LOCATION 6641 Genoa Ln, Genoa, NV 89411

2. LOCATION W 1/2 1/4 NE 1/4 Sec. 13 T. 13 N/S R. 19 E/W Douglas County
PERMIT NO. (Issued by Water Resources) 17-150-020 (Parcel No.) Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	2'	2'
Brown Sand		2'	20	18'
Brn Sand + Grvl		20'	36'	16'
Brown Clay		36'	40'	4'
Brn Sand		40'	80'	40'
Brn Clay		80'	91'	11'
Brn Sand + Grvl		91'	110'	19'
Brn Clay		110'	120'	10'
Brn-Gray-Red				
Sand	X	120'	150	30'

Date started 9-6-01, 19
Date completed 9-7-01, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		1 HR

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 152 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	150

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	12	130

Perforations:
Type perforation Factory
Size perforation 3/32"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 2 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA PUMP & DRILLING (Contractor)
Address P.O. BOX 2227 (Contractor)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Marty Lopez
By driller performing actual drilling on site or contractor
Date 9-20-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627