WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84479
Permit No.
Basin 92-B

NOTICE OF INTENT NO. 38684

1. OWNER W.B. McDonald
MAILING ADDRESS 9095 No. Virginia
Reno, NV 89506

ADDRESS AT WELL LOCATION
9201 No. Virginia
Reno, NV 89506

2. LOCATION NW ¼ NE ¼ Sec 16 T 20 (N)S R 19 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) 082-270-01 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay | | 0 | 28 | |
| Brown Clay, Gravel | | | | |
| and Boulders | | 28 | 219 | |
| Green Volcanics | | 219 | 252 | |
| Yellow Phorphry | | 252 | 257 | |
| Green Volcanics | | 257 | 365 | |

Date started 8-28-01, 19
Date completed 8-30-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Approx | 8 + | 360 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 365 Feet Depth Cased 365 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 12 ¼ | Inches | 0 | Feet | 19 | Feet |
| 9 7/8 | Inches | 19 | Feet | 365 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 14 | .188 | -1 | 365 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3
From 265 feet to 365 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 365 feet

9. WATER LEVEL
Static water level 201 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MILLER & SONS DRILLING CO. (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 9-26-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627