WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84481
Permit No.
Basin 105

NOTICE OF INTENT NO. 44923

1. OWNER Bob Lasell
MAILING ADDRESS 796 Foothill Rd.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 796 Foothill Rd.
Gardnerville, Nv.

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T 12N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) 19-191-17 (Parcel No.) Foothill (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite Boulders	no	115	128	13
Gray DG	no	128	135	7
Brown DG	no	135	205	70
Brown DG with Clay	no	205	209	4
gray DG	yes	209	230	21

Date started 8/9/2001, 19__
Date completed 8/13/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	5Ft	1 Hr.

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8 Inches		115 Feet	230 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	115	230
			230	

Perforations:
Type perforation factory milled
Size perforation 1/8 X 3 6 row
From 190 feet to 230 feet
From 230 feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal N/A
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd. (Contractor)
Fallon, Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed (By driller performing actual drilling on-site or contractor)
Date 8/18/2001

USE ADDITIONAL SHEETS IF NECESSARY