

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44924

1. OWNER Seward Homes ADDRESS AT WELL LOCATION 1815 Sullivan
 MAILING ADDRESS P.O. Box 642 Gardnerville Nv.
Gardnerville, Nv., NV 89410

2. LOCATION NE 1/4 NW 1/4 Sec. 24 T 12N N/S R 20E E Douglas County
 PERMIT NO. 1220-24-201-009 Ruhenstroth
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Unsorted Gravel and boulders	no	0	97	97
Cemented gravel and boulders	no	97	162	65
med. small gravel and sand	no	162	204	42
Sandy clay	no	204	247	43
sand and small gravel	yes	247	263	16
sandy clay	no	263	271	8
sand and fine gravel	yes	271	280	9
sandy clay	no	280	293	13
gravel	yes	293	300	7

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To		
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>60</u> Feet		
<u>9 7/8</u> Inches	<u>60</u> Feet	<u>300</u> Feet		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation Factory milled
 Size perforation 1/8 X 3 6 row

From <u>220</u> feet to <u>260</u> feet
From <u>280</u> feet to <u>300</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50ft
 Placement Method: Pumped Poured

Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc. Contractor
 Address 7780 Curry Rd. Contractor
Fallon Nv. 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed [Signature]
By driller performing actual drilling on-site or contractor
 Date 8/26/2001

Date started 8/14/2001, 19____
 Date completed 8/27/2001, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>+ - 40</u>		<u>2 hrs</u>

CLOSED 25 AUG 10:55 AM
 STATE ENGINEERING OFFICE