

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 84538
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45917

1. OWNER Marge Godde ADDRESS AT WELL LOCATION 1581 Orchard
 MAILING ADDRESS 232 Sierra Shadow Gardnerville, Nv 89410
 2. LOCATION NW 1/4 NE 1/4 Sec 34 T. 13 N. R. 20 E Douglas County
 PERMIT NO. 132034001015 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown SAND+CLAY		0	10	10
Brown SAND+GRAVEL		10	40	30
Grey+Black GRAVEL		40	60	20
Brown+Grey ROCK		60	80	20
Brown CLAY		80	110	30
Brown+Grey SAND+GRAVEL		110	160	50
Brown CLAY		160	200	40
Brown Grey-brange SAND+GRAVEL		200	242	42

8. WELL CONSTRUCTION
 Depth Drilled 242 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 105/8 Inches To 242 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>67/8</u>		<u>1/8</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation FACTORY
 Size perforation _____
 From 240 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 242 feet to 100 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 7-9-01, 19____
 Date completed 7-13-01, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>200+</u>		<u>1 HR.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA PUMP & DRILLING
 Address P.O. BOX 2227 DAYTON, NV 89403
 Nevada contractor's license number 0046357
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Monty Lopez
 By driller performing actual drilling on site or contractor
 Date 7-18-01