WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84566
Permit No.
Basin 87

NOTICE OF INTENT NO. 46651

1. OWNER Rick & Jeanne Marsh
MAILING ADDRESS 5801 Mount Rose Highway
Reno, NV 89511

ADDRESS AT WELL LOCATION 5801 Mt.Rose Hwy
Reno,Nevada 89511

2. LOCATION SW 1/4 SW 1/4 Sec. 25 T 18N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources | 150-021-24 Parcel No. | Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Down Hole Circulation Problem,No Return		100	150	50
Hard Rock-Pee size Gravel-Sand	x	150	210	60
T.D. 210		210		

Date started 10/08/2001, 19__
Date completed 10/10/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
36	210	1/2 hour
36	195	1/2 hour
30	170	1 hour
18	145	1 hour
8.5	120	1 hour

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6-1/8 Inches		100 Feet	210 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	6.96	.188	80	210

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 170 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal In Place
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service
Contractor
Address P.O. Box 60130
Contractor
Reno,Nevada
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed Larry Weld
By driller performing actual drilling on-site or contractor
Date 10/30/2001

USE ADDITIONAL SHEETS IF NECESSARY