#3

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84584
Permit No. 45723
Basin 71

NOTICE OF INTENT No. 1475

1. OWNER Garrett Van Diest
MAILING ADDRESS P.O. Box 867
Winnemucca, Nevada 89446

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NE ¼ Sec. 26 T. 34N N/S R. 37 E. Pershing County
PERMIT NO. OK 45723 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
Sand + gravel		5	60	
Sandy Clay		60	80	
Sand + Sandstone		80	120	
Sand + Course Sand		120	140	
Clay + gravel		140	170	
Course Sand + gravel		170	178	
Course Sand + Sandstone		178	200	
Course Sand + Clay		200	250	
Course Sand		250	254	
Sandy Clay + Course Sand		254	300	
" " " "		300	330	
Course Sand + gravel		330	335	
Sandy Clay + gravel		335	420	

RECEIVED 01 OCT 23 AM 11:03 STATE ENGINEER'S OFFICE

Date started 5-20-83, 19
Date completed 5-25-83, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	420 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.25	0	400

Perforations:
Type perforation Torch Cut
Size perforation 1/4 x 4 inches
From 100 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Armstrong Bros Well Drilling (Contractor)
Address 4710 Hwy 40 West (Contractor)
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 5348
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 620
Signed Joe Armstrong (By driller performing actual drilling on site or contractor)
Date 6-2-83

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627