

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 84691  
 Permit No. \_\_\_\_\_  
 Basin 212  
 NOTICE OF INTENT NO. 46650

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Tosco Marketing Co. ADDRESS AT WELL LOCATION 3401 Boulder Hwy. Las Vegas  
 MAILING ADDRESS 3550 N. Central Avenue. 4th Floor  
Phoenix, AZ 85012  
 2. LOCATION SW 1/4 SW 1/4 Sec. 6 T 21N N/S R 62E E Clark County  
 PERMIT NO. 161-06-402-001 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Drpoint

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brownish Orange D.G with multi colored rock</u>		<u>0</u>	<u>4.0'</u>	<u>4.0'</u>
<u>Brown &amp; White clay with brown sand mix</u>		<u>4.0'</u>	<u>6.0'</u>	<u>2.0'</u>
<u>Brown &amp; White Clay mix</u>		<u>6.0'</u>	<u>10.0'</u>	<u>4.0'</u>
<u>Brown &amp; Dark Green Clay</u>		<u>10.0'</u>	<u>12.0'</u>	<u>2.0'</u>
<u>Dark Green Clay</u>		<u>12.0'</u>	<u>13.0'</u>	<u>1.0'</u>
<u>Dark Brown Clay</u>		<u>13.0'</u>	<u>14.0'</u>	<u>1.0'</u>
<u>Dark Green Clay</u>		<u>14.0'</u>	<u>16.2'</u>	<u>2.2'</u>
<u>G.P - 2 T.D16.2</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 16.2 Feet Depth Cased 16.2 Feet  
 HOLE DIAMETER (BIT SIZE)  

	From	To		
<u>6</u> Inches	<u>0</u> Feet	<u>6'</u>	Feet	
<u>2-1/4</u> Inches	<u>6'</u>	<u>16.2</u>	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>34"</u>	<u>.278</u>	<u>sch 80 pvc</u>	<u>0</u>	<u>16.2</u>
<u>34"</u>	<u>.278</u>	<u>sch 80 pvc</u>	<u>7.0'</u>	<u>16.2</u>

Perforations:  
 Type perforation factory sawed  
 Size perforation .010  
 From 7.0' feet to 16.2 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal 5.0' Bent/Grout  
 Placement Method:  Pumped  Poured  
 Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Gravel Packed:  Yes  No  
 From 16.2' feet to 7.0' feet

9. WATER LEVEL  
 Static water level dry feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P Pump & Well Service Contractor  
 Address P.O Box 60130 Contractor  
Reno, Nevada 89506  
 Nevada contractor's license number issued by the State Contractor's Board 0035387-B  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
 Signed Steve Webb  
 By driller performing actual drilling on-site or contractor  
 Date 11/04/2001

Date started 11/01/2001, 19\_\_\_\_  
 Date completed 11/03/2001, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailor			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

