WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84644
Permit No.
Basin 212

NOTICE OF INTENT NO. 46650

1. OWNER Tosco Marketing Co.
MAILING ADDRESS 3550 N.Central Avenue. 4th Floor
Phoenix, AZ 85012

ADDRESS AT WELL LOCATION 3401 Boulder Hwy. Las Vegas

2. LOCATION SW 1/4 SW 1/4 Sec. 6 T 21N S N/S R 62E E Clark County
PERMIT NO. (Issued by Water Resources) 161-06-402-001 Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Drpoint

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brownish Orange D.G with multi colored rock		0	4.0'	4.0'
Brown & White clay with brown sand mix		4.0'	6.0'	2.0'
Brown & White Clay mix		6.0'	10.0'	4.0'
Brown & Dark Green Clay		10.0'	12.0'	2.0'
Dark Green Clay		12.0'	13.0'	1.0'
G.P-5 T.D13.0				

Date started 11/01/2001 , 19__
Date completed 11/03/2001 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 13.0 Feet Depth Cased 13.0 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	6'	Feet
2-1/4	Inches	6'	Feet	13.0	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3\4"	.278	sch 80 pvc	0	13.0

Perforations:
Type perforation factory sawed
Size perforation .010
From feet to feet
From 7.0 feet to 13.0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 5.0' Bent/Grout
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 13.0 feet to 7.0' feet

9. WATER LEVEL
Static water level dry feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P Pump & Well Service (Contractor)
Address P.O Box 60130 (Contractor)
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0035387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed (By driller performing actual drilling on-site or contractor)
Date 11/04/2001

USE ADDITIONAL SHEETS IF NECESSARY