WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 84674
Permit No.
Basin 212

NOTICE OF INTENT NO. 21732

1. OWNER Las Vegas Paving
MAILING ADDRESS 4470 S. Decatur Las Vegas NV
ADDRESS AT WELL LOCATION Flamingo Wash - West @ Boulder Highway

2. LOCATION SE ¼ NW ¼ Sec. 7 T. 21 N/S R. 62 E. Clark County
PERMIT NO. DW1138 (Issued by Water Resources) 161-07-256-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other Temp Dewatering

PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Station 52+00 | | | | |
| Dirty Sand/Clay | | 0 | 3 | |
| Gravel | 4 | 3 | 8 | |
| Gravel/Clay Mix | | 8 | 20 | |
| Clay | | 20 | 25 | |

Date started 11-16, 2001
Date completed 11-16, 2001

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 24 | 0 | 25 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | PVC | Sch-40 | 0 | 25 |
| | | | | |
| | | | | |

Perforations:
Type perforation Slot
Size perforation .030
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 25 feet

9. WATER LEVEL
Static water level 4 feet below land surface
Artesian flow Good G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering (Contractor)
Address 836 E Maitland Ontario Ca (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031214
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-16-01

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627