WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84689
Permit No.
Basin 212

NOTICE OF INTENT NO. 22000 IS

1. OWNER Clark County Sanitation District
MAILING ADDRESS 5857 E. Flamingo Rd.
Las Vegas, NV 89122

ADDRESS AT WELL LOCATION VEGAS VALLEY AND HOLLYWOOD BOULEVARD, NEAR LAS VEGAS WASH

2. LOCATION NE ¼ SE ¼ Sec. 15 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 161-15-701-002 Subdivision Name MW-1

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY CLAY		0	9	9
CLAY-RICH GRAVEL		9	20	11
CLAY-RICH SAND		20	35	15

DCNR/DWR
RECEIVED
NOV 16 2001
LAS VEGAS OFFICE

Date started 1 NOVEMBER 2001
Date completed 1 NOVEMBER 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5 1/2 Inches		0 Feet	35 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		.308	0	35

Perforations:
Type perforation FACTORY SLOT PVC
Size perforation 0.020 INCH
From 20 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2, 2-22 BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 22 feet to 35 feet

9. WATER LEVEL
Static water level 11.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 69.8 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants (Contractor)
Address 731 Pilot Road (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627