

Log No. 84707
Permit No. 212
Basin: 212

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22701

1. OWNER CHEURON USA Products Company
MAILING ADDRESS 145 S. STATE COLLEGE BLVD
QUETA CALIFORNIA #92822

ADDRESS AT WELL LOCATION 4800 ALPINE PLACE
LAS VEGAS NEVADA 89107

2. LOCATION SE 1/4 SE 1/4 Sec 36 T 20 N 0 R 60 E MD 69 W CLARK County
PERMIT NO. 138-36-802-009 Parcel No. 138-36-802-009 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. Domestic Municipal/Industrial Monitor Stock Test Cable Rotary RVC
 Other HUSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------|--------------|-----------|------------|------------|
| <u>ASPHALT</u> | | <u>0</u> | <u>1m</u> | |
| <u>ILL</u> | | <u>0</u> | <u>15'</u> | |
| <u>GRAVEL, silty sm</u> | | <u>15</u> | <u>21</u> | |
| <u>CLAY</u> | | <u>21</u> | <u>30</u> | |

8. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet
HOLE DIAMETER (BIT SIZE)
10 Inches From 0 Feet 30 Feet
10 Inches From 0 Feet 30 Feet
Inches From 0 Feet 30 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4</u> | | <u>5/16</u> | <u>40</u> | <u>0</u> |
| | | | <u>0</u> | <u>30</u> |

Perforations:

Type perforation machine slotted
Size perforation 3/8" x 30
From 0 feet to 30 feet
From 0 feet to 30 feet
From 0 feet to 30 feet
From 0 feet to 30 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 3 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 0 feet to 30 feet

9. WATER LEVEL

Static water level: 17 feet below land surface
Artesian flow: 17 G.P.M. P.S.I.
Water temperature 61 °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EAELS Drilling LLC Contractor
Address: 7150 PLACID RD Contractor
LV NV 89119 51266
Nevada contractor's license number 51266
issued by the State Contractor's Board
Nevada driller's license number issued by the M2107
Division of Water Resources, the on-site driller.

Signed Anthony Huard
By driller performing actual drilling on site or contractor
Date 8-13-01

Date started 8-9-01 19
Date completed 8-12-01 19

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift
G.P.M. 11 Draw Down (Feet Below Static) 30m
Time (Hours)