

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 84754  
 Permit No. 55141  
 Basin 61

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47552

1. OWNER **Barrick Goldstrike Mines** VD97-17 ADDRESS AT WELL LOCATION **Barrick Goldstrike minesite, north of Carlin, NV**  
 MAILING ADDRESS **P.O. Box 29**  
**Elko, NV 89803**

2. LOCATION **NW** 1/4 **NE** 1/4 Sec. **19** T **36N** N/S R **50E** E **Eureka** County  
 PERMIT NO. **55141** Issued by Water Resources Parcel No. **N/A** Subdivision Name **N/A**

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned by pumping abantonite via tremie from 800' to static water level, then poured hole plug and abantonite to 20', and capped with neat cement.				
Quantities Used: Neat cement: 7 cu.ft. Hole plug: 14 cu.ft. Abantonite: 247 .ft.				

8. WELL CONSTRUCTION  
 Depth Drilled **810** Feet Depth Cased **801** Feet

HOLE DIAMETER (BIT SIZE)

From	To
17.75 Inches	0 Feet 19 Feet
9.875 Inches	19 Feet 810 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12.75	33.38	0.250	0	19
6.625	17.02	0.250	+2	801

Perforations:  
 Type perforation **Louwer**  
 Size perforation **0.125"**

From	To
120 feet	801 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **100'**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **100** feet to **810** feet

9. WATER LEVEL  
 Static water level **617** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started **10/3/2001** 19  
 Date completed **10/3/2001** 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Lang Exploratory Drilling** Contractor  
 Address **P.O. Box 5279** Contractor  
**Elko, NV 89802-5279**  
 Nevada contractor's license number issued by the State Contractor's Board **0021976**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1796**

Signed *Ron Berreandt*  
 By driller performing actual drilling on-site or contractor  
 Date **10/16/01**

B.S.T.L