WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84793
Permit No.
Basin 212

NOTICE OF INTENT NO. 22935

1. OWNER Terrible Herbst Oil Co.
MAILING ADDRESS 5195 S. Las Vegas Blvd Las Vegas, NV 89119
ADDRESS AT WELL LOCATION 3550 W. Sahara Ave. Las Vegas, NV 89102

2. LOCATION SW ¼ SW ¼ Sec. 5 T. 21 N/S R. 61 E. Clark County
PERMIT NO. N/A (Issued by Water Resources) 162-05-402-005 (Parcel No.) Station 116 (Subdivision Name)

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill (Type II)		0	2	2
Silty Clay		2	14	12
Caliche (Beige)		14	17	3
Gray Clay w/ gravel	W	17	25	8

DCNR/DWR RECEIVED DEC 06 2001 LAS VEGAS OFFICE

Date started 11-5-01, 19
Date completed 11-5-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25' Feet Depth Cased 25' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10¼	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch 40	0.29	0	25

Perforations:
Type perforation Machine Slotted
Size perforation .020 in
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6'-8' Bent plug
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 25 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 60.1 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MCCS Drilling (Contractor)
Address 1930 Village Center Cir Ste 3-382 (Contractor)
Las Vegas, NV 89134
Nevada contractor's license number issued by the State Contractor's Board 47851
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044-TL
Signed Jason C Sorrell (By driller performing actual drilling on site or contractor)
Date 11-10-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627