REC 10

WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84820
Permit No.
Basin 212

NOTICE OF INTENT NO. 22482

1. OWNER BASIC ENVIRONMENTAL CO LLC
MAILING ADDRESS 875 W WARM SPRINGS
Henderson NV 89015

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 5 T. 22 N/S R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) 17405-301-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PALE BROWN SILTY GRAVEL W/SAND		0	27.5	27.5
BROWN SILTY CLAY W/SAND		27.5	30	2.5
LIGHT BROWNISH GRAY TO WHITE BROWNISH GRAY SANDY LEAN CLAY		30	32.5	2.5
PALE OLIVE GYPSIFEROUS FAT CLAY W/SAND		32.5	50	18.5
PALE BROWN SAND		50	55	5
PALE OLIVE W/GYPSUM		55	57.5	2.5
BROWN GYP. LEAN CLAY WITH SAND		57.5	62.5	5
PALE OLIVE FAT CLAY		62.5	65	2.5
LIGHT GREENISH GREY CLAY		65	70	5
PALE BROWN GYP. W/SAND		70	87.5	17.5

DCNR/DWR Received OCT 5 2001 LAS VEGAS OFFICE

Date started 9-19-01, 19
Date completed 9-21-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 87.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	90 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	87.5

Perforations:
Type perforation MACHINE
Size perforation 1020
From 72.5 feet to 87.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 68.5
Placement Method: ☑ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 70.5 feet to 87.5 feet

9. WATER LEVEL
Static water level 78.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling LLC (Contractor)
Address 7150 PLACID RD (Contractor)
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor [illegible] (By driller performing actual drilling on site or contractor)
Date 10-10-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627