WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84854
Permit No.
Basin 212

NOTICE OF INTENT NO. 22003

1. OWNER Clark County Sanitation District
MAILING ADDRESS 5857 E. Flamingo Rd.
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION LAS VEGAS WASH AND VALLEY ROAD, NEAR SPILLWAY

2. LOCATION SW ¼ SE ¼ Sec. 30 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) 160-30-000-003 (Parcel No.) MW-7 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND WITH GRAVEL		0	38	38
CLAY —		38		
MUDDY CREEK FM.			50	12

DCNR/DWR
RECEIVED
NOV 16 2001
LAS VEGAS OFFICE

Date started 10-24, 19 01
Date completed 10-24, 19 01

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5½ Inches		0 Feet	50 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		.308	0	50

Perforations:
Type perforation FACTORY SLOT PVC
Size perforation 0.020 INCH
From 40 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-3, 3-38
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 38 feet to 50 feet

9. WATER LEVEL
Static water level 4.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 69.7 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants (Contractor)
Address 731 Pilot Rd., Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627