

OFFICE USE ONLY  
 Log No. 84855  
 Permit No. 212  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22003

1. OWNER Clark County Sanitation District ADDRESS AT WELL LOCATION LAS VEGAS WASH AND UTILITY ROAD, NEAR SPILLWAY  
 MAILING ADDRESS 5857 E. Flamingo Rd. Las Vegas, NV 89122

2. LOCATION SW 1/4 SE 1/4 Sec. 30 T 21 NDR 63 E CLARK County  
 PERMIT NO. 166-30-000-003 Issued by Water Resources Parcel No. Subdivision Name MWB

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND with GRAVEL		0	20	20
SAUDY clay		20	30	30
SAND		50	53	3
CLAY		53	56	3
GRAVEL		56	60	4

8. WELL CONSTRUCTION  
 Depth Drilled 60 Feet Depth Cased 60 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 5 1/2 Inches To 0 Feet 6 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		308	0	60

Perforations:  
 Type perforation FACTORY SLOT PVC  
 Size perforation 0.010 IN GA  
 From 40 feet to 60 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 2-3, 3-35  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 35 feet to 60 feet

DCNR/DWR  
 RECEIVED  
 NOV 16 2001

LAS VEGAS OFFICE

Date started 10-24, 1901  
 Date completed 10-24, 1901

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 14.2 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 68 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Converse Consultants Contractor  
 Address 731 Pilot Rd., Suite H Las Vegas, NV 89119 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 48947  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_