

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 04920
 Permit No. _____
 Basin 94
 NOTICE OF INTENT NO. 44311

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER James A. Beaumont ADDRESS AT WELL LOCATION 400 Britt Rd Reno NV 89506
 MAILING ADDRESS P.O. Box 98 Beckworth CA 96129
 2. LOCATION N 1/4 NW 1/4 Sec 87 T. 22 S. R. 19 E. Washoe County
 PERMIT NO. 079-382-26 Parcel No. _____ Subdivision Name Rancho Sierra (Red Rock Estates)

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--------------|--------------|------|-----|-----------|
| Hard pan | | 0 | 8 | 8 |
| Sand | | 8 | 18 | 10 |
| DG with clay | | 18 | 201 | 83 |
| Rock Frac. | X | 201 | 205 | 4 |
| Gray Clay | | 205 | 260 | 55 |
| Rock Frac. | X | 260 | 265 | 5 |
| Gray Clay | | 265 | 270 | 5 |
| Rock Frac. | X | 270 | 278 | 8 |
| Rock Hard | | 278 | 287 | 9 |
| Rock Frac. | X | 287 | 292 | 5 |
| Gray Clay | | 292 | 300 | 8 |

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>18</u> | <u>1/4</u> | <u>2+</u> | <u>200</u> |

Perforations:
 Type perforation Saw slot
 Size perforation 3/16 x 3/4
 From _____ feet to _____ feet
 From 200 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olewnski Drilling & Pump Contractor
 Address 15045 Red Rock Rd Reno NV 89506 Contractor
 Nevada contractor's license number 50343 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed John F. Olewnski
 By driller performing actual drilling on site or contractor
 Date 10/16/01

Date started 10/3/01
 Date completed 10/11/01

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>10</u> | <u>231</u> | <u>4</u> |

RECEIVED
 0 NOV 11 AM 11:11
 STATE ENGINEERS OFFICE