WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84922
Permit No.
Basin 49

NOTICE OF INTENT NO. 44984

1. OWNER JOSE BECERRA
MAILING ADDRESS Unk
ADDRESS AT WELL LOCATION None

2. LOCATION NW ¼ NW ¼ Sec. 7 T. 34 N/S R. 56 E. ELKO County
PERMIT NO. Waiver # R-390 (Issued by Water Resources) 032-006-013 (Parcel No.) Last Chance Ranch Unit #3 Blk F, Lot 13 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	39	39
Gravel, sand, clay (heavy water flow)	vrw	39	44	5
Clay (volcanic ash)		44	155	111
Sand	r	155	160	5
Shale	1	160	192	32
Soft black sandstone (major aquifer)	vrw	192	209	17
Shale		209	219	10
T.D. 219				

Date started 8/23/01, 19
Date completed 9/6/01, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	70	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 219 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
8 Inches		60 Feet	219 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1.5	219

Perforations:
Type perforation Torch cut
Size perforation
From 155 feet to 160 feet
From 182 feet to 212 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☑ Pumped to 35 ☑ Poured to 5
Seal Type: ☑ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No Bentonite 35-45
From 60 feet to 219 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING CO. (Contractor)
Address 203 PINE ST. (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed Jane Y. Muth (By driller performing actual drilling on site or contractor)
Date 9-13-01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627