

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45793

1. OWNER Jim Turner  
 MAILING ADDRESS P.O. Box 54  
Brawley, California 92227  
 ADDRESS AT WELL LOCATION Green Ranch  
6 Miles NE of Cherry Creek, Nevada

2. LOCATION NW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 17 T. 25 N & R. 64 E. White Pine County  
 PERMIT NO. 58376  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Gravel & Clay		5	10	5
Gravel & Sand		10	60	50
Course Water Bearing				
Gravel	X	60	70	10
Clay & Course Gravel		70	80	10
Clay with Sand & Gravel Stringers		80	110	30
Clay with Course Gravel		110	135	25
Clay		135	145	10
Sand & Gravel with Clay Seams		145	165	20
Course Gravel & Sand	X	165	170	5
Sand & Gravel with Clay Seams		170	185	15
Clay & Course Gravel		185	200	15

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
20 Inches From 0 Feet To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	0	200

Perforations:  
 Type perforation Factory  
 Size perforation 120 Slot 16 Rows  
 From 60 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 Feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

Date started July 26 2001  
 Date completed August 20 2001

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	450	148	3

9. 47 WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc.  
 Address 557 Ely Avenue  
Ely, Nevada 89301  
 Nevada contractor's license number 14790  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1793  
 Division of Water Resources, the on-site driller  
 Signed Rich Lewis By Jonell D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date August 28, 2001