

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 84945
 Permit No. _____
 Basin 89
 NOTICE OF INTENT NO. 46865

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Mike Dobson
 MAILING ADDRESS 150 Jackdaw Carson City, NV 89704
 2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 17N
 PERMIT NO. _____ Parcel No. 050-411-05
 Issued by Water Resources

ADDRESS AT WELL LOCATION 150 Jackdaw Carson City, Nevada 89704
 N/S R 20E E Washoe County
New Washoe City Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sands		0	133	133
Brown Clay and sand		133	147	14
Fractured rock		147	162	15
Quartz		162	208	46
Sandy Clay		208	218	10
Quartz		218	241	23
fractured Rock	x	241	260	19
T.D. 260 feet		260		

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10-5/8 Inches To 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>260</u>

Perforations:
 Type perforation factory sawed
 Size perforation 3/32 x 3
 From _____ 140 feet to _____ 160 feet
 From _____ 200 feet to _____ 220 feet
 From _____ 240 feet to _____ 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 _____ feet to 260 _____ feet

9. WATER LEVEL
 Static water level 75 _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Contractor
 Address P.O. Box 60130 Contractor

Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 0035387-B
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 08/31/2001

Date started 08/14/2001 _____, 19____
 Date completed 08/23/2001 _____, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>5</u>	<u>100</u>	<u>30 min</u>	<input checked="" type="checkbox"/>
<u>15</u>	<u>125</u>	<u>30 min</u>	
<u>20</u>	<u>200</u>	<u>1 hour</u>	
<u>25</u>	<u>225</u>	<u>2 hour</u>	
<u>30</u>	<u>260</u>	<u>2 hour</u>	