COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85000
Permit No.
Basin 103

NOTICE OF INTENT NO. 46379

1. OWNER PARAGON ASSOCIATES, INC.
MAILING ADDRESS P.O. BOX 20130
CARSON CITY, NV 89721

ADDRESS AT WELL LOCATION 2996 HWY 50 EAST
DAYTON, NV 89403

2. LOCATION NW ¼ NW ¼ Sec 12 T 16 N R 21 E LYON County

PERMIT NO. M/O 1232 (Issued by Water Resources) | 16-402-04 (Parcel No.) | DAYTON WASTEWATER TREATMENT POND (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
HARDPAN CLAY		3	15	12
COURSE DG SANDS		15	36	21
BROWN SANDY CLAY		36	52	16
COURSE DG SANDS AND SMALL GRANITE GRAVELS	X	52	76	24
BROWN SANDY CLAY		76	85	9

RECEIVED 01 NOV 13 PM 8:59 STATE ENGINEER'S OFFICE

Date started 10/14, 20 01
Date completed 10/14, 20 01

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	10	1 HR

8. WELL CONSTRUCTION

Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4	Inches	0 Feet	85 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	6.53	.250	0	85
CERT	LOCK	PVC	CASING	

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation .002
From 40 feet to 50 feet
From 60 feet to 70 ~~20~~ feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 40' Bentonite Grout ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 40 feet to 85 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M 10 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L. Hack
By driller performing actual drilling on site or contractor
Date 10/17/01

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429