WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85027
Permit No.
Basin 49

NOTICE OF INTENT NO. 45449

1. OWNER DUSTY SHIPP
MAILING ADDRESS 182 WEST BULLION ROAD #10
ELKO,, NV 89801

ADDRESS AT WELL LOCATION 26TH STREET, LOT 15, BLOCK 15

2. LOCATION SW 1/4 SE 1/4 Sec. 31 T 34N N/S R 55E E ELKO County
PERMIT NO. Issued by Water Resources | 064015015 Parcel No. | MVR #9 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	4	4
GRAVEL		4	15	11
CLAY		15	37	22
CEMENTED GRAVEL		37	58	21
SANDSTONE		58	109	51
CLAY		109	136	27
GRAVEL		136	138	2
CLAY		138	154	.
GRAVEL & SAND	X	154	180	26

Date started 8/28/2001, 19__
Date completed 8/29/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	45		2.5

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	180

Perforations:
Type perforation MILL SLOT
Size perforation 3/16 X 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. Contractor
Address P.O. BOX 525 Contractor
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1584
Signed Sharel C. Fertig By driller performing actual drilling on-site or contractor
Date 9/21/2001

USE ADDITIONAL SHEETS IF NECESSARY