



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46600

1. OWNER Denny Lamm & Livestock ADDRESS AT WELL LOCATION 5 miles Northwest off SR 140
 MAILING ADDRESS HC 73 Box 13738 OW Wilder Road
Burns, OR 97720

2. LOCATION SW 1/4 SE 1/4 Sec 31 T 47 N R 31 E County Humboldt
 PERMIT NO. 66966-T Parcel No. 02-101-01 Subdivision Name Humboldt
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
check STATIC for No H2O	Bottom	360'		
Set up TRIP IN Pump 28 Bags of ABANTOMITE 9, Batches of 9 lb + per Gallow Fluid				
check STATIC 122'				
Pour 15 Bags 3/4" chips Down well Bring level to 30'				
Pump 10 BAGS 3 Batches 14+ lb per Gallow Cement				
They had Extracted 4" From 260 To 400 previously From well to try & get H2O to Flow into well 6" was Rotten Box ABOVE WATER Thus they went with A Replacement well				

8. WELL CONSTRUCTION * 280'
 Depth Drilled 400 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
10"	0	280	Feet
6"	280	400	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation ?
 Size perforation ?

From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From.....feet to.....feet

9. WATER LEVEL
 Static water level No H2O in hole feet below land surface
 Artesian flow NO G.P.M. P.S.I.
 Water temperature None °F Quality None

Date started May 1st 2001
 Date completed May 2nd 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FRED S Anderson Contractor
 Address 10760 Grass Valley Road
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1375

Signed [Signature]
 Date July 3 01