

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 85047
 Permit No. _____
 Basin 76

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 45228

1. OWNER Nevada Cement ADDRESS AT WELL LOCATION I-80 exit 46 Fernley
 MAILING ADDRESS P.O. Box 840
Fernley, NV 89408

2. LOCATION NW 1/4 NW 1/4 Sec. 11 T 20N N/S R 24E E Lyon County
 PERMIT NO. 24451 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set trimmie pipe to 255 ft. and pumped 10,810 lbs. of neat cement from the bottom of the hole to 100 ft. level-no bentonite added. pumped 6 sack grout from 100 ft. to surface to finish filling the well. conductor & seal on original log from 0-150 ft. Not necessary to perf well because of 150 ft. conductor per Tom Gallagher.				
ABANDONMENT				

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>		<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/23/01, 19
 Date completed 4/23/01, 19

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6/19/01

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)

RECEIVED
 JUN 20 AM 11:23
 DIVISION OF WATER RESOURCES



